



- FD308 FIRE RESISTING DOOR WITH SMOKE SEAL AND INTUMESCENT STRIP
- SC POSITIVE CLOSING DEVICE
- SC/A MAGNETIC HOLD OPEN DEVICE
- VP VISION PANEL
- PH DOORS FITTED WITH PANDA BOLTS WITH NOTICE
- LOOK WITHOUT KEY OR BARREL BOLT NOTICES AND SIGNS TO ACCORD WITH BS5499
- NI FIRE NOTICE
- ND FIRE DOOR KEEP SHUT
- TO BE UNLOCKED WHEN PREMISES ARE OCCUPIED
- INTERNALLY ILLUMINATED EXIT PROGRAM (ARROW INDICATES DIRECTION OF ESCAPE) (M - MAINTAINED)
- AREA COVERED BY EMERGENCY LIGHTING
- ② FIRE ALARM CALL POINT
- AD ADDRESS WARNING DEVICE
- AREA COVERED BY HEAT DETECTOR
- AREA COVERED BY SMOKE DETECTOR (= OPTICAL)
- HE EXTINGUISHER WATER
- FE EXTINGUISHER FOAM
- FD EXTINGUISHER DRY POWDER
- CE EXTINGUISHER CARBON DIOXIDE
- ACTV
- EXTENTS OF LICENSED AREA
- ALL ACTIVITIES INCLUDING TRAVEL

/// EXTERIOR

SITE
INDIA COTTAGE
RONGWOOD

Draw title
LICENSING PLAN
MARCH 2021

Scale
1:100 @A3